

18 August 1953

Electrical Work in Monitoring Rooms

Electrical (Refer to Drawing No. ~~9-6~~ 5-6)

Quantity	Item	
1	Outlet No. 1	This is a wall switch which controls Outlets No. 2 (referred to as S1 on Dwg. 9-6)
3	Outlet No. 2	Duplex Recept. (referred to as B on Dwg. 9-6)
1	Outlet No. 3	Duplex Recept. (referred to as C on Dwg. 9-6)
1	Outlet No. 4	Duplex Recept.

Communications (Refer to Drawings No. 7-5) and 5-6)

Electrical subcontractor to install boxes and conduit. Government
will provide wire and do the wiring.

1	Outlet B	Appleton Box No. 5 or equal.
1	Cabinet G	Columbia 12" x 12" x 4" Type A or equal.
1	Outlet H	GE cabinet 12" x 6" x 3" Type A or equal to be installed only in Monitoring Rooms 2, 7, 9 and 14.